

Ref. No: CA/SCM/OT/50/2024-2025

May 8th, 2025,

Addendum No. 2

To All Bidders,

CLARIFICATION/AMENDMENTS FOR TENDER FOR PROPOSED SUPPLY, INSTALLATION, TESTING AND COMMISSIONING OF 1NO. 800KVA GENERATOR SET AND MAINTENANCE OF THREE (3) GENERATOR SETS AT CA OFFICES NAIROBI COUNTY, TENDER NO.CA/SCM/OT/50/2024-2025-

Please refer to the above-mentioned tender.

According to clause 10.1 of the tender document shared with bidders, the Authority wishes amend and respond to the clarifications sought out as follows:

NO.	CLARIFICATION QUESTIONS	CA RESPONSE
1.	There is already an existing 800Amps distribution board with ATS and PFC bank at site. There is no mention on whether we need to decommission the existing board and fit the new synchronization panel from both the BOQ and scope of work provided.	The existing panel board will be decommissioned and be replaced with the new panel board as appropriate
2.	On item one above. Clarify whether the new sync panel with ATS should have below listed the same way the current existing set up is. i) PFC Bank ii) power distribution board	The ATS and synchronization panel is one item. Configuration of the new panel and existing PFC bank panel will be done on site during execution

ALL other conditions of the initial tender remain unchanged.

Yours Faithfully,



Peter Mwangi
FOR: DIRECTOR GENERAL /CEO